


SCHEDULE OF ITEMS

ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1	20mm / 25mm TAPPING BAND	8	TEMPORARY END FITTING TO BE SUPPLIED BY CITY WEST WATER (FOR RECYCLED WATER AREAS ONLY)
2	20mm / 25mm BALL VALVE RELEVANT WATER CORPORATION MAY UTILISE A FERRULE & BEND IN SOME CASES	9	ELBOW
3	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM	10	TIMBER STAKE
4	POLYETHYLENE TO COPPER CONNECTOR	11	HOSE BIB TAP
5	DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 (CLAUSE 5.10 & 5.11) AND LOCAL COUNCIL REQUIREMENTS	12	HOSE CONNECTION VACUUM BREAKER
6	20mm / 25mm RIGHT ANGLE BALL VALVE	13	TUBE BUSH
7	20mm / 25mm APPROVED CITY WEST WATER SUPPLIED WATER METER THE TYPE OF WATER METERS (20mm AND 25mm). WHERE WATER METERS INCORPORATE INTEGRAL DUAL CHECK VALVES, PLUMBERS ARE TO MAKE THEIR OWN ASSESSMENT WHETHER TO FIT AN ADDITIONAL CONTAINMENT BACKFLOW PREVENTION DEVICE	14	BRASS PLUG
			SEE GENERAL NOTES FOR FURTHER INFORMATION

STANDARD LEGEND

⊗	V	Valve
○	M	Meter
□	D.B.	Dirt Box
—	S.P.	Straight Piece
⊥	T.F.	Testing Ferrule
▭	L.S.	Line Strainer
⌌	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V.T	Single Check Valve Testable
⌌	S.C.D.A.T.	Single Check Detector Assembly Testable



CWW DESIGNED	STEVE WEBB	PROJECT NUMBER	
DATE	21/10/2019		
DRAWN	DONNA TOLENTINO	MELWAY REFERENCE	
DATE	21/10/2019		
CHECKED		AUTHORISED	
DATE		DATE	



City West Water
 20 - 25mm GENERAL WATER SERVICE (WET TAPPING)
 LOW HAZZARD
 RESIDENTIAL / COMMERCIAL / INDUSTRIAL
 TYPICAL ARRANGEMENT

SCALE: AS SHOWN @A3
SHEET: 1 OF 1
DRAWING No.: WAT-TYP-002
REV 0