


SCHEDULE OF ITEMS			
ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1	20mm TAPPING BAND / PRE-TAPPED CONNECTOR	8	TEMPORARY END FITTING TO BE SUPPLIED BY CITY WEST WATER (FOR RECYCLED WATER AREAS ONLY)
2	20mm BALL VALVE	9	ELBOW
3	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM	10	TIMBER STAKE
4	POLYETHYLENE TO COPPER CONNECTOR	11	HOSE BIB TAP
5	DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 AND LOCAL COUNCIL REQUIREMENTS	12	HOSE CONNECTION VACUUM BREAKER
6	20mm RIGHT ANGLE BALL VALVE	13	TUBE BUSH
7	20mm APPROVED CITY WEST WATER SUPPLIED WATER METER INCORPORATING DUAL CHECK VALVE	14	BRASS PLUG
			SEE GENERAL NOTES FOR FURTHER INFORMATION

STANDARD LEGEND	
⊗	V Valve
○	M Meter
□	D.B. Dirt Box
—	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V.T. Single Check Valve Testable
⌌	S.C.D.A.T. Single Check Detector Assembly Testable



				CWW DESIGNED	STEVE WEBB	PROJECT NUMBER	
				DATE	21/10/2019		
				DRAWN	DONNA TOLENTINO	MELWAY REFERENCE	
				DATE	21/10/2019		
0	FOR REVIEW	00.00.00		CHECKED		AUTHORISED	
REV	DESCRIPTION	DATE	APPROVED	DATE		DATE	



**City West Water**  
 20mm DRINKING WATER (DRY TAPPING)  
 LOW HAZZARD  
 RESIDENTIAL INSTALLED BY CITY WEST WATER  
 TYPICAL ARRANGEMENT

SCALE: AS SHOWN @A3
SHEET: 1 OF 1
DRAWING No.: WAT-TYP-003
REV 0